

Water and Sewer
PO Box 330316 • 3071 SW 38 Avenue
Miami, Florida 33233-3016
T 305-665-7471

VIA ELECTRONIC CORRESPONDENCE

miamidade.gov
September 12, 2014

CCN: 58702
File No: 8DC.20.32

Chief, Clean Water Enforcement Branch
Water Protection Division
ATTN: Brad Ammons
U.S. Environmental Protection Agency, Region 4
61 Forsyth Street, S.W.
Atlanta, Georgia 30303
ammons.brad@epa.gov

Florida Department of Environmental Protection
Southeast District – Suite 200
400 N. Congress Ave.
West Palm Beach, FL 33401
Attn: Compliance/Enforcement Section
Sed.wastewater@dep.state.fl.us

**RE: Consent Decree (Case: No. 1:12-cv-24400-FAM), Reference DOJ Case No. 90-5-1-1-4022/1
Section IX – Reporting Requirements, Paragraph 32 – Quarterly Report
Amendment to 2014 Quarterly Report No. 1 Revised SSO Table**

Dear Sirs:

On behalf of Miami-Dade County, the Miami-Dade Water and Sewer Department (MDWASD) submits to both the United States Environmental Protection Agency (EPA) and the State of Florida Department of Environmental Protection (FDEP) an amendment to the 2014 Quarterly Report No. 1 Revised SSO Table. The attached document titled Amendment to 2014 Quarterly Report No. 1 Revised SSO Table includes the information that contained clerical errors and the amended information.


I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Should you have any questions regarding this matter, please call me at (786) 552-8571.

Sincerely,

Juan Carlos Arteaga, AIA, NCARB, CBO, APA
Deputy Director

Attachment: Amendment to 2014 Quarterly Report No. 1 Revised SSO Table



ec: Chief, Environmental Enforcement Section
Environment and Natural Resources Division
U.S. Department of Justice
P.O. Box 7611
Ben Franklin Station
Washington, D.C. 20044-7611
Re: DOJ No. 90-5-1-1-4022/1
walter.benjamin.fisherow@usdoj.gov

Rachael Amy Kamons
Environmental Enforcement Section
U.S. Department of Justice
P.O. Box 7611
Ben Franklin Station
Washington, D.C. 20044-7611
rachael.kamons@usdoj.gov

Florida Department of Environmental Protection
Southeast District – Suite 200
400 N. Congress Ave.
West Palm Beach, FL 33401
Attn: Compliance/Enforcement Section
linda.brien@dep.state.fl.us
Michael.Hambor@dep.state.fl.us
Lisa.M.Self@dep.state.fl.us

Jack Osterholt
Director, Miami-Dade Regulatory and
Economic Resources
111 NW 1st St
29th Floor
Miami, FL 33128
Josterholt@miamidade.gov

ebc: Bill Johnson
L. Douglas Yoder
Ralph Terrero
Eduardo Vega
Bertha Goldenberg
Henry Gillman
Frances Morris
Sherry Negahban
Richard O'Rourke
Howard Fallon
Robert Fergen
Al Galambos
Rod Lovett
Lance Llewelyn
Juan Bedoya
Rolando Roque
Donna Fries
Vincent Flick
Marlyce Benjamin-Gray
Lee N Hefty (Asst. Director RER)
Carlos Hernandez (RER)
Rashid Istambouli (RER)
David Haywood (CD PMCM)
Rosanne Cardozo (CD PMCM)

Amendment to 2014 Quarterly Report No. 1 Revised SSO Table

Information As Reported in the 2014 Quarterly Report No. 1 Revised SSO Table

Date	Time	Location	Source	Est. Duration hr:min:sec	Est. Volume gallons	Destination	Waters of the U.S.	Cause	Immediate Fix	Long Term Fix?	
										Reqd (Yes/No)	Solution
04-Jan-14	12:41 PM	Saint Lo Blvd & Rabual Rd	FM	3:41	650,000	Canal 100	Yes	10" AC FM broken due to corrosion. 840' from canal	Repaired 8" FM broken by contractor	Yes	All AC force mains to be replaced per Consent Decree
04-Jan-14	7:49 PM	SW 156th St & Old Dixie Hwy	FM	1:49	468	Land	No	8" AC FM broken by contractor (Roland Enterprise) while removing shrubbery - no location provided - limited asbuilts for HAFB acquired system	Repaired corroded section of force main	Yes	All AC force mains to be replaced per Consent Decree
11-Mar-14	5:00 PM	NW 70th St & NW 72nd Ave	FM	0:30	3,000	Land	No	48" PCCP Force main broken by contractor - probably 2 years ago	Emergency contracted the repair	No	Isolated incident, no further action required

Amendment to 2014 Quarterly Report No.1 Revised SSO Table

Date	Time	Location	Source	Est. Duration hr:min:sec	Est. Volume gallons	Destination	Waters of the U.S.	Cause	Immediate Fix	Long Term Fix?	
										Reqd (Yes/No)	Solution
04-Jan-14	7:49 PM	SW 156th St & Old Dixie Hwy	FM	3:41	650,000	Canal 100	Yes	10" AC FM broken due to corrosion. 840' from canal	Repaired 8" FM broken by contractor	Yes	All AC force mains to be replaced per Consent Decree
04-Jan-14	12:41 PM	Saint Lo Blvd & Rabual Rd	FM	1:49	468	Land	No	8" AC FM broken by contractor (Roland Enterprise) while removing shrubbery - no location provided - limited asbuilts for HAFB acquired system	Repaired corroded section of force main	Yes	All AC force mains to be replaced per Consent Decree
11-Mar-14	5:00 PM	NW 70th St & NW 72nd Ave	FM	24:30	3,000	Land	No	48" PCCP Force main broken by contractor - probably 2 years ago	Emergency contracted the repair	No	Isolated incident, no further action required